

UINTAH FIRE



152 E 100 N Vernal, UT 84078
 Office # 435-781-6755
 Fax # 435-781-4962

Fire Safety Inspection Report

DISTRICT

Inspector _____ # _____

| | |
|-----------------|------------|
| Business Name: | Date: |
| Address: | Occ. Type: |
| Representative: | Phone # |

Inspection based on the International Fire Code, 2012 Edition, and NFPA Standards, section referenced

| General | | | | Housekeeping | | | |
|----------------------------------|---------|----|-----|--------------------------------------|---------|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Address Visible | 505.1 | | | Waste not allowed to accumulate | 304.1 | | |
| Unobstructed Hydrant/FDC | 507.5.4 | | | Oily Rags in Approved Container | 304.3.1 | | |
| Key Box Accessible, Keys Checked | 506.1 | | | Proper Clearance to Ignition Sources | 305.1 | | |
| Fire Access Road Unobstructed | 503.4 | | | Fueled Equipment stored properly | 313.1 | | |

| Electrical | | | | Mechanical | | | |
|--|-------|----|-----|---|--------------|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Electrical Boxes, Outlets Covered | 605.6 | | | Dump and Cont. 5 ft from bldg | 315.3.1 | | |
| Panel Accessible 30" | 605.3 | | | No Comb. In equipment room | 315.3 | | |
| Extension cords are not substituted For permanent wiring | 605.5 | | | Gas Meter and piping subject to Damage protected from traffic | 603.9 312 | | |

| Emergency Lighting | | | | Propane | | | |
|---------------------------------|--------|----|-----|----------------------------------|--------|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Means of Egress illuminated | 1006.1 | | | Container protected from traffic | 6107.4 | | |
| Egress emergency power operable | 1006.3 | | | No smoking signs | 6107.2 | | |
| Generator | 604.1 | | | No comb, weeds 10 ft | 6107.3 | | |

| Exits | | | | Fire Sprinkler Systems | | | |
|---|--------------------------|----|-----|--|--------------------|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Exit open able without key , special Knowledge or effort-no flush bolts | 1008.1.8.1 1008.1.8.4 | | | Sprinkler System inspected/tested | 901.6.1,2 | | |
| Means of egress unobstructed | 1003.6 | | | Records Available upon request | 903.5 | | |
| Exit signs at required exits | 1011.1 | | | Storage 18" below heads 24" below Ceiling without sprinklers | 315.3.1 | | |
| Exit signs illuminated | 1011.3 | | | Sprinkler system on and monitored | 903.4 | | |
| Exit door swings out 50+ Occup. And panic hardware | 1008.1.2 1008.1.10 | | | Stock of spare sprinklers & wrench | NFPA13 6.2.9 | | |
| | | | | FDC Protective Caps & Accessible | NFPA13 8.16.2.4 | | |

| Extinguishers | | | | Hood Suppression System | | | |
|-----------------------------------|---------|----|-----|--------------------------------------|----------|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Inspection & Service is Current | 906.2.1 | | | Class K extinguisher in Kitchen-30ft | 904.11.5 | | |
| Properly Mounted, Visible, Acces. | 906.5 | | | Current Inspection and Service Rec | 904.11.6 | | |

| Fire Alarm and Detection | | | | General | | | |
|---------------------------------|-------|----|-----|-------------------------|-----|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Alarm System Inspected & Tested | 907.2 | | | Verify Business License | | | |

| Flammable/Combustible Liquids | | | | Storage | | | |
|--|------------|----|-----|--|----------|----|-----|
| | Yes | No | N/A | | Yes | No | N/A |
| Under 10 gal, Apprvd Container | 5704.3.4.4 | | | Compressed Gas Cylinder secured | 5303.5.3 | | |
| 10 gal or more-liquid storage Cabinet (Maint. Operation use) | 5704.3.4.4 | | | Attic & Concealed space protected By 1 hour Const. or sprinklers | 315.3.4 | | |

Notes: _____

The granting of this fire clearance only implies that a reasonable degree of fire safety exists at the time of the inspection. Any hazardous conditions and/or violation of adopted codes, not herein cited or missed during this inspection, does not imply acceptance or approval of such conditions and/or violations.

Representative Signature: _____ Inspectors Signature: _____